



Test Report Summary

Product Information	
Licence Number:	209109
Licensee:	ACSO
Product Identification	TH331
Test Specifications	
Tested Application:	Electric Floor Heating
Temperature Sensor	
- Type:	NTC10k
- Time Constant:	0.3 Mins
Actuator Identification	
- Type:	None
Valve Identification	
- Characteristic	None
AV Acronym	
Fan Speed (For Fan Coil Applications)	
- Characteristic	None
Test Result	
Temperature Control Accuracy C_A according EN 15500	0.6

30 July 2015

Brussels

A handwritten signature in black ink, appearing to read 'Peter Hug'.

Managing Director Dr. Peter Hug

eu.bac