

**ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-22-005050**

**Only the original French edition of this procès-verbal is authentic.  
Seule l'édition originale en français du présent procès-verbal fait foi.**

**The French PROCES VERBAL is valid for 5 years starting on January 04<sup>th</sup>, 2023**

<b>Applicant</b>	ACSO 11 bis, Boulevard Carnot 81270 LABASTIDE ROUAIROUX France
<b>Sample reference</b>	DYNASOFT HYGIENE
<b>Brief description provided by the applicant</b>	The product is a slab of (600 x 600) mm glass veil decoration with carbon film, all assembled by gluing. This slab is composed, from the inside to the outside, of an insulator with non-woven glass veil, a glue based on polyvinyl acetane copolymer in aqueous phase, a carbon film with connectors, a glue based on polyvinyl acetane copolymer in aqueous phase, and an insulator with white glass veil.
<b>Mass per unit area determined by the laboratory</b>	3,4 kg/m <sup>2</sup> ± 10%
<b>Thickness measured by the laboratory</b>	39 mm ± 10%
<b>Colour</b>	White
<b>End-use condition</b>	Radiant modular ceiling

**Standard of tests:**

- **NF P 92-507 (2004)** - Building - Interior fitting materials - Classification according to their reaction to fire
- **NF P 92-501 (1995)** - Reaction to fire tests Radiation test used for rigid materials, or for materials on rigid substrates (flooring and finishes) of all thicknesses, and for flexible materials thicker than 5 mm

**Classification obtained in the official Procès Verbal:**

**M1**

**Valid for any application for which the product is not subjected to the CE marking.**

**Durability of the classification (NFP 92-512: 1986):** Supposedly unlimited

*Taking into account the criteria resulting from the tests described in the test report n°EFR-22-005222-EPI from January 11<sup>th</sup>, 2023.*

*This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.115-27 of the Consumer Code and the Law of June 3<sup>rd</sup>, 1994.*

*Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5<sup>th</sup>, 1959.*

Les Avenières Veyrins-Thuellin, on January 11th, 2023